PART#: MLD-FG-1872 (FIG.2) DESCRIPTION: 18"X36" SUCTION OUTLET COVER

FLOOR GPM

4,518

WALL GPM

NA

OPEN AREA 686.88

The above noted product has been certified to comply with section #1404 of the Virginia Graeme Baker (VGBA) Pool & Spa Safety Act. Further information can be obtained by visiting www.lawsonaquatics.com and/or http://www.lawsonaquatics.com/certification.htm

DATE OF MANUFACTURE:

The born-on date will be shown on each product as follows: The first dial shows the year of manufacture (ex: 2009) and the second dial shows the month of manufacture (ex: December).

YEAR (14 (19) 10) 11

MONTH $\begin{pmatrix} 11 & 12 & 1 \\ 9 & & & 3 \\ 8 & 7 & 6 & 5 \end{pmatrix}$

Manufactured by Lawson Aquatics Inc. in Guang Dong Province, China,

Manufacturer recommends replacement after 10 years

Tested to ANSI/ASME 112.19.82007(addendum 8a2008) per Section 1404 of the Virginia Graeme Baker Act (VGB) Pool & Spa Safety Act- December 2008 Certified by NSF International, 789 N. Dixboro, Road, Ann Arbor, MI. 48113-0140 USA (USA): 800-NSF-MARK (+1) 734-769-8010.

